

Kullafolie, Water vapour control layer

Holder/Issued to

Kullaplast AB

Box 62, 26321 Höganäs

Organisation number: 556189-9948

Phone: +46 (0)42 36 26 00

E-mail: info@kullaplast.se , Web: www.kullaplast.se

Product description

Flexible sheet for waterproofing consisting of LD-Polyethene, with nominal thickness 0.12, 0.15 or 0.20 mm.

Intended use

Flexible sheet for waterproofing intended for mounting on walls, floors and ceilings.

Trade name

MATAKI Halotex, Luft- och Ångspärr,
MATAKI Halotex FP, Luft- och Ångspärr,
Teno, Luft- och Ångspärr,
RAW, Luft- och Ångspärr,
ISOVER, Luft- och Ångspärr or
Kullafolie, Luft- och Ångspärr

Approval

The products have been found to meet the requirements in the following sections of Boverket Building Regulations (BBR) issued by the National Board of Housing, Building and Planning, and the Planning and Building Act (PBL).

BBR

Moisture, General

6:51

Moisture safety, Air tightness

6:531

Moisture safety, Roofs and attic space

6:5325, second general recommendation,
fourth and fifth sentence

PBL

Energy management and thermal insulation

Chap. 8, 4§ section 6

Restriction of convection in underlying insulation

The products have been assessed against Certification rule CR128 appendix 1, Water vapour control layer.

Associated documents

Mounting instructions:

Mataki Halotex Luft- och Ångspärr, dated 2017-08-23

Mataki Halotex FP, Luft- och Ångspärr, dated 2020-04-20

Teno Luft- och Ångspärr, dated 2012-01-25

RAW Luft- och Ångspärr, dated 2017-10-10

ISOVER Luft- och Ångspärr, dated 2017-10-10

Kullafolie Luft- och Ångspärr, dated 2017-10-10

Certificate no. 2125/91 | 2020-04-20

RISE Research Institutes of Sweden AB | Certification

Box 857, SE-501 15 Borås, Sverige

Tel: +46 10-516 50 00

certifiering@ri.se | www.ri.se

2017-08-18



9P08866



Control

The factory production control (FPC) is monitored by an independent inspection body.
Control agreement: 210-12-0226, Inspection body: RISE

When the building proprietor performs inspection at the building site markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this approval and associated documents.

Manufacturing place

Production control includes the following place:
Factory code Plast 1/08.

Marking

The products are to be marked at the factory. The marking consists of print on every product and text on every packing supplied and includes:

Holder of certificate

Factory code*

P-mark*

Certification body

Product type designation

Certificate number*

Properties*

Water vapour resistance

Length, width

Consecutive manufacture no.*

Inspection body

Kullaplast AB alt. distributor

Plast 1/08



RISE Certifiering

Trade name

2125/91

"Luft och ångspärr"

Value

Value, value

No.

RISE

* Information to be on the product

Basis for judgement/approval

Report 89M30090/89M30121, F709543, 5P009106B, 6F007796B, 6F018897 and 7F009328A from SP Sveriges Tekniska Forskningsinstitut. Report 9F029754 from RISE Research Institutes of Sweden.

Comments

The product shall have a packing that prevents it from being exposed to UV-radiation during outdoor storage.

This approval supersedes the previous approval with the same number dated 2017-11-22.

Validity

Valid through 2022-10-17.

Johan Åkesson

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.

Certificate no. 2125/91 | 2020-04-20

RISE Research Institutes of Sweden AB | Certification